



Fire Inspection Report

conducted for

Palm Beach Life Safety Damage follow up

Inspection Type

Inspection

Contractor/ Owner

Palm Beach

Conducted on

9/28/20, 10:34 AM

Prepared by

T. Bryant

Address

22984 Perdido Beach Blvd

Completed on

9/28/20, 3:42 PM

Disclaimer

The inspector believes the information contained within this fire inspection report to be correct at the time of the affixed signature. The report is based on matters which were observed or came to the attention of the inspector during the day of the fire inspection and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.

Correction and abatement of violations of this code shall be the responsibility of the owner. Correct each violation, by complying with the notice, no more than three weeks from this inspection, unless otherwise specified. Contact the Fire Marshal at 251-981-6166 when violations are corrected.

Confidentiality Statement

In order to maintain the integrity and credibility of the fire inspection processes and to protect the parties involved, it is understood that the inspector will not divulge to unauthorized persons any information obtained during this fire inspection unless legally obligated to do so.

Audit

Question	Response	Details
Orange Beach Fire Marshal		
Inspection Outcome	Not Approved	<p>- 85 Troubles are present on the panel. Please contact contracted company in order to resolve.</p> <p>(901.6 Inspection, testing and maintenance. Fire detection and alarm systems, emergency alarm systems, gas detection systems, fire-extinguishing systems, mechanical smoke exhaust systems and smoke and heat vents shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Nonrequired fire protection systems and equipment shall be inspected, tested and maintained or removed.)</p>
Appendix 1	Appendix 2	

Media

Appendix 1

Appendix 2